



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 12/29/09

Code 19.2.2-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title R302.11 Fireblocking		Page 52
Proponent Lynn Madden	Title	
Address 9805 Chapel Road Centerville, IN 47330		Phone 765-623-1640
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Change item 4 in Section R302.11 Fireblocking to read as follows:</p> <p>4. At openings around vents, pipes, ducts, cables and wires at ceiling and floor level, with an approved material to resist the free passage of flame and products of combustion. The Approved materials filling this annular space shall not be required to meet the ASTM E 136 requirements. shall have demonstrated that they comply with materials listed in R302.11.1 or any of the following:</p> <p><u>a. Materials tested for noncombustibility in accordance with ASTM E 136.</u></p> <p><u>b. Materials tested under the fire conditions of ASTM E814 or UL1479.</u></p> <p><u>c. Materials tested for use as fireblocking material under the fire conditions of ASTM E 119 and installed in accordance with the specifications under which the material was tested.</u></p>		
REASON AND FISCAL IMPACT		
<p>This proposal brings forward amendment R602.8 fireblocking required from the 2005 Indiana Residential Code.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		